



Southwire®

GUIDE FOR
INSTALLATION OF
**BARE OVERHEAD
CONDUCTORS**



SOUTHWIRE.COM

OUR STORY

As a family business, Southwire proudly continues building on our commitment to environmental stewardship and corporate sustainability by prioritizing stakeholder expectations, and supporting the wellbeing of our communities and the environment in which we live. To help us meet this commitment, we organize our sustainability strategy around five core tenets: Growing Green, Living Well, Giving Back, Doing Right, and Building Worth.

We Deliver Power...Responsibly®

We remain committed to the sustainability of our company for the next 100 years and beyond. As we strengthen this commitment, we continue to work hard every day to discover, develop, and distribute sustainable solutions that exceed the expectations of our stakeholders around the world.

OUR MISSION

To be a **preferred provider** of solutions to the electrical industry by providing innovative products and services with exceptional quality.

OUR VALUES

Our **ONE Southwire** culture prioritizes the interests of our team members, customers, and communities through a continuous commitment to empowerment, trust, consistency, and inclusion.

OUR REACH

Nearly one in two new homes built in the United States contains our wire, and we produce half of the cable used to transmit and distribute electricity throughout the nation.

OUR PRODUCTS

Our product teams and dedicated resources work together to listen to and work with our customers, creating solutions that deliver unparalleled value through product innovation, safety, and efficiency.

OUR SERVICE

Service is more than a word or a phone number; it's a tangible support system that assists you through the entire project cycle; from our knowledgeable customer service team, to our experienced field sales team, we're there every step of the way.




TABLE OF CONTENTS

GUIDE FOR INSTALLATION OF **BARE OVERHEAD CONDUCTORS**

Introduction	4	Conductor Stringing and Sagging	10
Reel Handling and Storage	4	Sagging Methods.....	10
Conductor Oxidation	5	Conductor Repair	11
Conductor Staining	5	Miscellaneous.....	11
Conductor Handling	6		
Spooling and Training	6		
Installation Payoff	6		
Installation Bullwheel	7		
Stringing Sheeves.....	9		
Running Grounds	9		

INTRODUCTION

Southwire recommends that conductor installations be performed in accordance with IEEE 524 “Guide to the Installation of Overhead Transmission Line Conductors”. This guide is intended to summarize best practices for installing standard conductors.

REEL HANDLING AND STORAGE

Special care should be taken to ensure the conductor and reels are not damaged. Unloading equipment must never come in contact with the conductor. Lifting must be performed using a fork lift or crane as described below. When using a fork lift, the forks shall be placed under both flanges, with the flange facing the operator.

When using a crane, a spreader bar must be used in conjunction with either “J” hooks or an axle to prevent damage to the reel flange and conductor. “J” hooks should be placed in the arbor holes. Axles should be inserted through the arbor holes and lifted with straps.



Figure 1: Forklift handling of reels.




Figure 2: Crane handling of reels.

Reels should be stored away from physical and environmental hazards, such as chemicals. Conductor reels must be stored standing on their flanges in a flat, well drained area. The conductor must not be allowed to touch the ground.

CONDUCTOR OXIDATION

Exposure of conductor to air will cause oxidation to form on the conductor. Oxidation results from a chemical reaction between oxygen and aluminum, yielding an oxide layer on the conductor. While it is normal for oxidation to form, necessary steps should be taken to clean the conductor of oxidation at hardware application areas. The conductor must be brushed in these areas prior to installing hardware to ensure adequate metal-to-metal contact.




Figure 3: Oxidation on a conductor.

CONDUCTOR STAINING

When conductor reels are stored outdoors, moisture can accumulate on the conductor on the underside of the reel. If the moisture contains chemicals from the surrounding atmosphere, a black stain can appear on the conductor. This has been found to be more prevalent in nonspecular conductor because the drawing oils have been removed. Figure 4 shows the appearance of a water stain.

Water stains are a cosmetic issue; they have no adverse effect on the performance or service life of the conductor. In most environments, the conductor will darken in the first few months after the line is energized, and the stain will no longer be noticeable. Aluminum Association Technical Bulletin TR3, “Guidelines for Minimizing Water Staining of Aluminum” discusses this issue in detail and contains advice for avoiding water staining.



Figure 4: Oxidation on a conductor.

CONDUCTOR HANDLING

If conductor must contact the ground due to unavoidable circumstances, a smooth, rigid material may be laid in its path to prevent damage. Minor abrasions should not be a cause of concern; most can be sanded or buffed out. In an EHV application, the abrasion should be evaluated for possible corona concerns.

SPOOLING AND TRAINING

The minimum diameter for spooling is 30 times the conductor diameter. The minimum bending radius, or training radius, before permanent deformation occurs is 12 times the conductor diameter.

INSTALLATION PAYOFF

The conductor reel should be set up on a reel payoff stationed 40-50 feet (12-15 meters) behind and in line with the bullwheel tensioner. This will ensure that the conductor does not scrub the flanges as it is being unwound¹.



Figure 5: Payoff and bullwheel setup.

Proper adjustment of the fairlead roller guides is necessary to prevent scuffing of the conductor as it reeves through the bullwheel. Only enough braking tension should be applied to the reel to prevent the reel from over-rotating (free-spooling) when the pulling operation stops. A slight droop between the payoff and bullwheel is desirable, as this indicates low tension between the bullwheel and payoff. Back tension should be kept at a minimum. This is especially important for smaller conductor diameters and wooden reels². If too much back tension is applied, the conductor on the outer layer can “pull down” into the underlying layers, as in Figure 6.



Figure 6: Conductor pull-down.

¹ IEEE Standard 524-2016 pg. 62, ²IEEE Standard 524-2016 pg. 69

INSTALLATION BULLWHEEL

Only dual drum multi-groove bullwheel tensioners are recommended for multilayered conductor³. The bullwheel drums may be tilted or offset so that the offset will be approximately one-half the groove spacing⁴.

Semicircular grooves with depths of 0.5 or more times the conductor diameter and flare angles of 5-15° from vertical generally are recommended. For multilayer conductors, the number of grooves in the bullwheel must be sufficient to prevent the outer layer of wires from slipping through underlying layers. The minimum bottom groove diameter of the bullwheel should be 39 times the conductor diameter minus 4 inches (10 centimeters). Additional sizing charts and diagrams can be found in IEEE Standard 524⁵. Bullwheels must be properly sized and lined to prevent scuffing and damaging of the conductor.

The conductor should be reeved through the bullwheels such that, when facing in the direction of pull, the conductor will enter the bullwheel on the left side and exit from the right. This orientation is necessary to avoid any tendency to loosen the outer layer of strands⁵.

If lined, durable polymer-lined grooves are recommended to avoid permanent scuffing of the surface of the conductor. Semiconducting linings should not be relied on for grounding purposes⁵.



Figure 7: Dual drum bullwheel, courtesy of Oncor.

³ IEEE Standard 524-2016 pg. 52 , ⁴ IEEE Standard 524-2016 pg. 82

⁵ IEEE Standard 524-2016 pg. 52-53

INSTALLATION BULLWHEEL

It is important never to break the conductor over a small roller under high tension, as this can permanently damage the conductor. Figure 8 shows an example of the conductor traveling over a small roller (not recommended); Figure 9 shows a suitable roller diversion technique.

The bullwheel should be set up in line with the pull and 3-4 times as far from the base of the structure as the distance from the base of the structure to the height of the entrance block at the first structure⁶. This is important to ensure the conductor is not pulled over the entrance block at a large angle.



Figure 8: Adverse interaction of conductor with roller, courtesy of Transpower New Zealand.



Figure 9: Suitable technique for roller diversion, courtesy of Transpower New Zealand.




Figure 10: Orientation for bullsheel/payoff setup.

⁶ IEEE Standard 524-2016 pg. 61

STRINGING SHEAVES⁷

A minimum bottom groove diameter of 20 times the conductor diameter minus 8 inches (20 centimeters) is generally used for typical pulls [i.e. pulls less than 2 miles (3 kilometers) with level spans and minimal angles]. For pulls over 2 miles (3 kilometers) or with substantially uneven terrain, the bottom groove diameter should be increased by 4 inches (10 centimeters). **Bottom groove diameter should never be less than 12 times the conductor diameter.** Entrance sheaves are typically sized at 20 times the conductor diameter. Higher tension pulls or structures with a turning angle greater than 20° may also warrant larger sheaves. For angles between 20-45°, a bottom groove diameter of 25 times the conductor diameter is typically recommended. For angles up to 90°, two sheaves with bottom groove diameters of 25 times the conductor diameter are typically recommended. Sheaves on structures with a turning angle should be supported so that the conductor acts through the center line of the sheave. Measurement A in Figure 11 below shows where to measure the bottom groove diameter.

The minimum radius at the base of the groove is recommended to be 1.1 times the radius of the conductor. The location of this measurement is shown as Measurement B. Sheaves with a groove radius as above may, in general, be used with smaller conductors. However, the more layers of aluminum that exist, the more important it is to have a well-fitting groove.

The minimum depth of the groove should be 1.25 times the conductor diameter. This measurement is given as Measurement C. The flare of the grooves should be between 12-20° from vertical to facilitate the passage of swivels, grips, etc., and to contain the conductor for angled pulls.

If lined, sheaves should be lined with a durable polymer to protect against scratching of the conductor. Sheave bearings must be in good working condition and free-wheeling. Make sure all sheaves are in proper working order before use.




Figure 11: Measurements for stringing sheave.



Figure 12: Stringing sheave.

RUNNING GROUNDS⁸

Running grounds should be installed along two points in the pull—one between the reel stand or tensioner and first structure, and the other between the puller and last structure. Running grounds should be bonded to the established ground and free-wheeling. They should not be over tightened, as this could cause surface abrasion or birdcaging

⁷IEEE Standard 524-2016 pg. 55-57, ⁸IEEE Standard 524-2016 pg. 66

CONDUCTOR STRINGING AND SAGGING

To avoid damaging the conductor, tension stringing is recommended. The maximum recommended pulling tension during the stringing operation should not exceed that necessary to maintain clearances above obstructions on the ground or safety structures. Recommended stringing tensions are between 5-10% of the rated breaking strength (RBS) of the conductor and should not exceed 50% of sagging tensions. In circumstances where the tension must exceed 50% of sagging tensions, contact Southwire for a recommendation on creep correction. Typical pulling speeds are between 3-5 miles per hour (5-8 kilometers per hour)⁹.

Southwire recommends that any conductor be pulled up to sag and clipped in as soon as possible. The conductor should not be left in the sheaves for more than 24 hours before being pulled up to sag. If tension must be reduced after sagging (due to vibration concerns, equipment availability, etc.), the attachment points should be marked immediately after sagging. The conductor should be clipped in within 72 hours of stringing¹⁰. If a conductor must be left in the sheaves for an extended period of time, it should be left at a tension less than 50% of sagging tension (close to pulling tension). If this tension is exceeded, contact Southwire for a recommendation on creep correction.

SAGGING METHODS¹¹

Conductor sagging involves the use of stringing tables to determine the required sag or tension at a specific conductor temperature. Conductor temperature should be measured at the time of sagging using a conductor thermometer placed at or near the conductor. The conductor thermometer should be installed prior to sagging to allow for temperature stabilization. Conductor is often tensioned to the correct sag/tension using one of the following three methods: (1) stopwatch method, (2) transit method, or (3) dynamometer method.

Stopwatch Method

The stopwatch method involves jerking a rope connected to the conductor and measuring the time it takes the vibration wave to reflect a certain number of times. Three or five return waves usually provide an accurate measurement of sag. The governing equation for the stopwatch method can be seen below.

$$D = 48.3 \left(\frac{t}{2n} \right)^2$$

D = conductor sag, inches
t = time, seconds
n = number of return waves

Transit Method

The transit method includes three types of sagging methods: calculated angle of sight, calculated target, and horizontal line of sight. Choice of the best transit sagging method to use is determined by the terrain of the span in the right-of-way and span length. Tall structures on flat terrain and short spans indicate the calculated target or horizontal line of sight method would be most applicable. Steep slopes, long spans, and large sags indicate the calculated angle of sight method would be best.

Dynamometer Method

In the dynamometer method, a dynamometer is inserted in-line with the sagging equipment to get a direct measurement of line tension. To ensure accurate sagging, there should be minimal sheaves in the line section. This method works best on smaller conductors, shorter spans, and ruling spans containing one or two spans.

⁹ IEEE Standard 524-2016 pg. 68, ¹⁰ IEEE Standard 524-2016 pg. 78

¹¹ IEEE Standard 524-2016 pg. 73-74

CONDUCTOR REPAIR

Repair methods may include use of armor rods or a repair sleeve to reestablish the full current carrying capacity. Please consult the hardware manufacturer for their recommendation on use of armor rods or a repair sleeve.

Disclaimer: All conductor hardware must be approved by the hardware manufacturer for use with the conductor prior to installation. Please consult the hardware manufacturer for more information on proper application.

MISCELLANEOUS

Neither Southwire nor anyone else who has been involved in the creation, production, or delivery of this publication shall be liable for any direct, indirect, consequential, or incidental damages arising out of the use, the results of the use, or inability to use such publication, even if Southwire has been advised of the possibility of such damages or claim. Some states do not allow the exclusion or limitation for consequential incidental damages, so the above limitation may not apply to you.

REFERENCES

IEEE Standard 524-2016, "Guide to the Installation of Overhead Transmission Line Conductors."

OHCM Overhead Conductor Manual 3rd Edition. Springer, Paul. Holcombe, Charles. Person, Drew. and Armstrong, Allee. Southwire. 2018. Print

DISCLAIMER

This publication is a collection of items of general information related to the subject of overhead conductor. It is not intended to be nor should it be used as authority for design, construction, use, or installation. The design, construction, use, and installation of overhead conductor should only be undertaken by competent professionals in light of currently accepted design and engineering practices. While great care has been employed to ensure that the applications, tables, standards, references, and other information contained herein are free of errors, absolutely no warranties, either expressed or implied, are made as to the accuracy or completeness of any such material contained herein.

THOSE PREPARING AND/OR CONTRIBUTING TO THE PUBLICATION SPECIFICALLY DISCLAIM ANY WARRANTY OF ANY KIND, EITHER EXPRESSED OR IMPLIED. THE WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE ARE HEREBY SPECIFICALLY DISCLAIMED BY SOUTHWIRE AND ALL OTHER PARTIES INVOLVED IN THE CREATION, PRODUCTION, OR DELIVERY OF THIS PUBLICATION.



Southwire®

GUIDE FOR
INSTALLATION OF
**BARE OVERHEAD
CONDUCTORS**

get social with us:



/SOUTHWIRE



/SOUTHWIRE-COMPANY



@SOUTHWIRE



@SOUTHWIRE



SCAN TO LEARN MORE

WWW.SOUTHWIRE.COM

All Trademarks or Registered Trademarks (TM/®) are owned or licensed by Southwire Company.
Any other TM/®- Trademark or Registered Trademark of Southwire Company.